

In-Furnace Thermal Imaging for Process Optimisation for Energy Reduction and Asset Protection.



AIGMF 2023 – MUMBAI



Philippe Kerbois
Global Industry Manager - Glass



QUALITY CUSTOMER SOLUTIONS



SHORT INTRODUCTION

Philippe Kerbois

Global Industry Manager - Glass

- Philippe has extensive sales and project management experience from working in the steel, glass and automotive industries including Rockwell Automation and ABB where he was specifically involved in major robot-based factory automation projects.
- Having worked at AMETEK Land since 2012, Philippe initially managed the sales of infrared temperature measurement solutions into line builders and glass and steel furnace OEMs within France, however now he works very closely with the global glass market and is actively promoting the award-winning Near Infrared Borescope (NIR-B) Glass thermal imaging solution for glass furnaces.

philippe.kerbois@ametek.com


+33 (0) 6.75.38.39.87





NIRB Images in Glass Furnace





ROI Editor



Zoom

100 %

Reset



Palette



1700



1400

1585

1585

1585

1585

1585

1585

1585

1585

1585

1585

1585

1585

1585

0:00:00, 0000 MB 0:01:00, 0332 MB



SIM (NIR 2K) 127.0.0.1 127.0.0.1

127.0.0.1

127.0.0.1

127.0.0.1

X: Y: T:

Glass batch SIM

Live Analysis

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

Noir1Blanc V1

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

Batch Display

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

Left Reversal Analysis

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

Right Reversal Analysis

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:


X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:

X: Y: T:



IMAGEPRO-GLASS

LAND
AMETEK[®]
PROCESS & ANALYTICAL INSTRUMENTS



LAND PORTFOLIO IN GLASS APPLICATIONS

Complete temperature offering


- Leverage demand for the NIRB borescope to promote a wider portfolio packages including :
 - The Fiber Optics “Legend FG”
 - Lancom 4 Gas analyser
 - FLTs and LSPHDs for thin bath and Lehrs
- As installation becomes more critical – possible to integrate and provide AMEcare Advanced Services into the offering
- Thermal Surveys with NIRB 2K demonstrating benefits of NIRB
- More than 150 NIRBs implemented Worldwide in major producers in the Glass industry





Previous DGG/HVG Conference Papers:


- **2016** – Infrared temperature Measurement in Glass Melt Tanks
- **2017** – Controlling a Glass Furnace Using Thermal Imager
- **2018** – Infrared Temperature Measurement in Glass Melt Tank to optimize furnace operation & Nox
- **2019** – Criticality of Accuracy and Traceability of Temperature Calibration
- **2022** - Specific Energy Reduction through infra red furnace monitoring and optimisation



Equipment bundle Used:

NIR-B-2K-GLASS - Near Infrared Borescope Glass Solution

- 3,000,000 pixels each measuring temperature \equiv 3M Cyclops
- (Output of 100 x continuous measurement points via TCP/IP)
- Max, min and average temperatures with user defined emissivity.
- Patent Pending



Cyclops C100L

- Portable Infrared Thermometer
- Industry Standard
- Verify spot temperatures
- 550 to 3000° C
- 1022 to 5432° F



Lancom 4 – Portable Gas Analyser

- 9 Gas Analyser for NOx
- CO low • CO high • O2
- NO • NO2 • NOx
- CO2 • H2S • SO2 • CxHy





The survey kit comprises of the following equipment

Full survey kit in Storm case



2ft Water Cooled Jacket



NIR-B 2k camera, 2ft probe, range 1000-1800C.



25m Power and Ethernet cables.





THE BENEFITS IN FURNACE OPERATIONS “NOT JUST A PRETTY IMAGE”




QUALITY CUSTOMER SOLUTIONS





Remember the four Pillars of Benefits with Thermal Imaging NIR-B! This is not only a pretty image!

Thermocouple Verification



Optical-Thermal profiles with hot spots





Analysis						
Data	Temperatures in °C			Δ	E	%
	Max	Mean	Min			
Frame	1586,9	1523	1160,2	▲	1,00	-
ROI 1	1562,8	1535,6	1493,8	●	1,00	-
ROI 2	1549,3	1534,4	1506	●	1,00	-
ROI 3	1544,2	1525	1483	●	1,00	-
ROI 4	1523,1	1505,3	1474	●	1,00	-
ROI 5	1552,3	1539,4	1525,3	●	1,00	-
ROI 6	1559,7	1545,8	1531,8	●	1,00	-
ROI 7	1527,2	1507,1	1490,7	●	1,00	-
ROI 8	1556	1544,5	1531,6	●	1,00	-
ROI 9	1540,6	1529,1	1517,7	●	1,00	-
ROI 10	1510,8	1510,8	1510,8	●	1,00	-
ROI 11	1289	1253,5	1225,2	●	1,00	-
ROI 12	1398,5	1385,1	1371,4	●	1,00	-
ROI 13	1541,9	1521,7	1496,3	●	1,00	-


ROI Editor

Palette

1600

Zoom


16:9 100% - + Reset






Remember the four Pillars of Benefits of NIR-B

**BW Palette for Air ingress and
Batch pattern**



**Isotherms with 3 bands for hot
and cold spot locations**





FLAME SHAPE AND INTENSITY – MONO / RAINBOW / INTEGRATOR



- Highlights flame shape and areas of high intensity for combustion and emissions optimisation.
- Continuous real time Temperature data.
- Areas used to monitor Highest or Average or Lowest Temperature.
- Crown, Regenerator and Side Wall temperature monitoring.




Nitrogen Oxide NOx formation

There are typically 4 modes of NOx formation:

- Fuel NOx – from Nitrogen elements in fuel
- Prompt NOx – relatively low temperature reaction
- Feed NOx – from raw ingredients such as Niter in the past
- Thermal NOx - at temperatures in excess of 1600°C

The upper limit of the NIR B is 1800°C areas above the upper limit are shown in white colour, by adjusting the range limits to increase contrast it is possible to determine what parts of the flame are the hottest and thereby assess generation of thermal NOx.



In glass manufacture as a result of modern batch materials typically the greatest source of NOx is believed to be thermal according is by Thermal NOx. At temperatures in excess of 1600°C (2900°F) the Oxygen molecules in air start to dissociate into elemental atoms. The higher the process or flame temperature, the higher the dissociation and therefore the greater formation of NOx. In the hottest zone of the flame a super equilibrium level of Oxygen atoms exists.





IMAGEPro GLASS



**BATCH COVERAGE AND CROWN TEMPERATURES WITH
NIR-B 2K GLASS AND IPV2
CONTAINER GLASS FURNACES**



QUALITY CUSTOMER SOLUTIONS



Image Pro– Gateway to Infrared Control

- Connection with all Land Instrument solutions including LWIR
- Digital and analogue Inputs/outputs
- TCPIP, OPC UA server, Modbus server and SDK
- Modbus server for data exchange with DCS (100 zones of interest possible to be monitored)+RTMP for video streaming
- Built-in Communication for Celsian rMPC (EU Reference)
- Built-in Communication for GS – ESIII (EU Reference)
- Any DCS communication for SCADA data analysis (Zenon Platform) with existing Drivers (TCPIP Modbus or OPC)







Batch Coverage and Crown Temperatures

- ▀ Variation in Batch coverage has a direct impact on furnace temperatures . The temperature clearly drops when the batch moves to the front of the furnace. These ROIs can be used to set some alarms to the Furnace DCS and get a better efficient control of the batch coverage by adjustment of the batch charging direction:
 - ▀ Setting to have top 2D view of the melter with the Image Pro furnace configuration feature.
 - ▀ Setting of a ROI in front of the Throat.
 - ▀ Configuration of a Batch ROI in the coverage melting grid near the throat (ROIs in C4R2 for example).
 - ▀ Batch length can be adjusted.
- ▀ The Batch coverage in this critical ROI near the throat could be monitored to:
 - ▀ Avoid large amount (below 15%) of batch in this area even for large pull rates.
 - ▀ Prevent Glass Defects.








Batch Analysis with %



Thermal profiling for hot spot location on thermal profiling






0:00:00, 0000MB 0:01:00, 0331MB



SIM (NIR 2K) 127.0.0.1 62,0°C 32 ε: 0.95

Profiling+hot spot

Max: 1640°C Min: 1539°C



SIM Live Image Profiling+hot spot

Analysis


Data	Temperatures in °C			Δ	ε	↓
	Max	Mean	Min			
Frame	1796,3	1572,5	1274,7	▲	0,95	-
ROI 2	1584	1564,5	1547,6	●	-	-
ROI 3	1611,7	1599,4	1586,6	●	-	-
ROI 4	1635,7	1623,9	1607,6	●	-	-
ROI 5	1643,1	1628,8	1615,3	●	-	-
ROI 6	1599,9	1585,2	1566,7	●	-	-
ROI 7	1598,6	1588,2	1575,1	●	-	-
ROI 8	1588,7	1578	1566,4	●	-	-
ROI 9	1569,1	1550,7	1535,3	●	-	-
ROI 10	1596	1578,9	1539,3	●	-	-
ROI 11	1602,3	1589,3	1559,8	●	-	-
ROI 12	1640,1	1615,5	1554,1	●	-	-

X: Y: T:


ROI Editor



Palette




Zoom



Glass Batch

Live Analysis



Batch Analysis


	C1	C2	C3	C4	Total
R1	98%	98%	98%	98%	98%
R2	43%	68%	62%	58%	58%
R3	59%	62%	68%	58%	62%
R4	44%	53%	56%	48%	50%
Total	61%	70%	71%	65%	67%




Batch Display

Batch Overlay	Visible
Batch Matrix	Visible
Batch Percent	Visible
Max Temperature	Visible
Mean Temperature	Hidden
Min Temperature	Hidden
Text Color	A

Palette




Left Reversal Analysis



X: Y: T: 11/10/2020 23:14

Right Reversal Analysis





Batch coverage and Reversal analysis



ImagePro Glass 2

- More Stable interface with possible multiple displays , Interface External Flame Detection
- Essentially the same as IPV1 Glass based on more reliable , quick and efficient IPV2 engine
- Batch analyser based on trapezoid geometry with flame detection






ImagePro2 Glass – new features


Flow Direction for multi locations

- Glass flow direction can be configured in furnace settings
- Towards** : Glass flow towards camera (existing)
- Away**: Glass flow away from camera
- If flow direction away from camera is selected then Batch display will be flipped

Away



Towards





ImagePro2 Glass – new features

External Flame Detection

There are now 2 types of flame detection (select in furnace settings)


Automatic

I/O

Left and Right flame's status can be controlled from IO by data pairing the following tags


IsLeftFlameActive

IsRightFlameActive







Isotherms





Flames optimisation with integration mode








Why to use NIR-B 2K on glass furnaces? Extended Benefits

- /// Possible Thermal Surveys with transportable NIR-B combining bundles Lancom 4 and Cyclops C100
 - /// Potential energy reduction with combustion optimization on every furnaces
 - /// Heat-up features at starting point with thermal references
 - /// Demonstration of recovery post repair with temporary oxy burners during repairs
 - /// Preventive maintenance
 - /// Needs to include this tool to best practices part of training sessions for optimisation
- /// Digitalisation with thermal distribution and bird eyes pictures
 - /// Potential to have data analysis for Expert System or SCADA through the furnace of the DCS (Zenon platform , Crowley Carbon or any data analysis solutions)
 - /// Existing communication with Expert system
 - /// Simple Batch control with Image pro Glass for basic analysis
 - /// Combustion and flames optimization for improved heat balance
- /// Traceability and Data for quality management
 - /// All furnaces images saved for future enquiries and reference points for quality controls
- /// Extended life of assets and improved daily furnace operations






LAND
AMETEK

Date : 11/01/2017

Time : 12:10:12



Emiss : 0.95

End Firing from Right to Left


4 Ports Clearly visible on firing side

3 Ports Clearly visible on exhaust side. Port 2 looks hot.



Date : 11/01/2017

Time : 12:10:12




Emiss : 0.95




End Firing Right to Left

Temperature range band reduced to improve contrast and clarity of image.



End Firing Right to Left


Profile is clearly skewed on the exhaust side.



LAND
AMETEK

Date : 11/01/2017

Time : 12:10:12



Emiss : 0.95

T.Max 1590
T.Min 1570


T.Max 1570
T.Min 1550

T.Max 1550
T.Min 1530



End Firing Right to Left


20 Degree Isotherms show
the skewed profile



LAND
AMETEK

Date : 11/01/2017

Time : 12:10:12




Emiss : 0.95

End Firing Right to Left

Palette 5 indicates the maximum contrast


Port 4 on Firing side is hottest but Port 2 on the exhaust side is the hottest.



LAND
AMETEK

Date : 11/01/2017

Time : 12:10:12




Emiss : 0.95

End Firing Right to Left

Palette 5 indicates the maximum contrast

Port 4 on Firing side is hottest but Port 2 on the exhaust side is the hottest.




LAND

AMETEK

Date : 11/01/2017

Time : 12:10:12




Emiss : 0.95

End Firing Right to Left

Palette 5 indicates the maximum contrast

Port 4 on Firing side is hottest but Port 2 on the exhaust side is the hottest.


The reality is that Port 4 on the LHS is partially blocked and flue gases are heading to Port 3.



LAND
AMETEK

Date : 11/01/2017

Time : 12:10:12



Emiss : 0.95

End Firing Right to Left

Palette 5 indicates the maximum contrast

Port 4 on Firing side is hottest but Port 2 on the exhaust side is the hottest.

The reality is that Port 4 on the LHS is partially blocked and flue gases are heading to Port 3.


The reason port 2 is the hottest s because Port 1 is also partially blocked!



Negative Image Showing Cooling (10/10/2016)

End of Firing Left to Right

End of Firing Right to Left











End of Firing L-R

01/09/14

10/10/16

15/03/17











End of Firing R-L

01/09/14

10/10/16

15/03/17





0:00:00, 0000 MB 0:01:00, 0332 MB



SIM (NIR 2K) 127.0.0.1 100% 1.00

X: Y: T:

ROI Editor



Zoom

100 % - + Reset




Palette



1700


1585

1400



Glass batch SIM

Live Analysis



X: Y: T:

Batch Display

Batch Overlay Visible

Matrix Settings

Batch Matrix Visible

Batch Percent Visible

Max Temperature Visible

Mean Temperature Hidden

Min Temperature Hidden


Text Color A

Left Reversal Analysis




X: Y: T: 14/09/2022 13:58

Right Reversal Analysis



X: Y: T: 14/09/2022 14:09





WWW.AMETEK-LAND.COM